



**CENTRAL PLANTS, INC.**

A SUBSIDIARY OF  
PACIFIC ENTERPRISES  
ENERGY MANAGEMENT SERVICES

633  
West  
Fifth Street,  
Los Angeles,  
California  
90071-2606

Mailing Address  
P.O. Box 30900  
Los Angeles,  
California  
90030-0900

Facsimile  
(213) 489-2998  
Telephone  
(213) 895-5600

February 27, 1998

South Coast Air Quality Management District  
Title V Administration/Grp A Draft Permits  
P.O. Box 4830  
Diamond Bar, CA 91765-0830

Greetings:

Enclosed are the required Title V Permit documents, following review of the initial draft, for the following Central Plants (CPI) facility:

Central Plants, Inc./Century City  
RECLAIM Facility ID 011034  
2052 Century Park East  
Los Angeles, CA 90067

Please note that one of the RECLAIM devices at this facility has been inoperative for some time. Specifically, Boiler #5 (Device D41) suffered a catastrophic failure (natural gas explosion) on May 9, 1996, and again on May 16, 1997. It has been inoperative since the latter date. In order to repair Device D41, CPI submitted an application to the South Coast Air Quality Management District (District) for a Permit to Construct, including changes to Device D41's NOx emission limits. Although the permit has not yet been issued, communications with the District suggest issuance is imminent (mid-March). Device D41 will then be repaired and returned to service no later than June 30, 1998. A certified CEMS will be attached shortly thereafter, data will routinely be transmitted to the District, and Device D26 will be returned to standby service. These steps will bring the facility back into compliance with respect to these two devices.

If there is any question, or if I can expedite permit processing, please contact me at (213) 895-5676.

Sincerely,

Stanley W. Zison, Ph.D., M.P.H.  
Director, Environmental Compliance